



The Compliance Management Group

Issues

A CERTIFICATE OF TEST:

To

*APC
85 Rangeway Road
Bldg. #2
Billerica, MA 01862-0318*

For

Product: Uninterruptible Power Supply

**Models: SUA1500I, IBMR1500I (MTM# 2130-R6X, Option# 39Y8883)
SUA1000I, IBMR1000I (MTM# 2130-R4X, Option# 39Y8879)**

Date: November 6, 2006

The Compliance Management Group, a U.S. and internationally approved test laboratory, attests that compliance testing was completed satisfactorily on the aforementioned equipment as specified by the manufacturer and reported in test report number: 66755.c1.rev2. The Compliance Management Group acknowledges that the Equipment Under Test was found to have passed the following standards:

EN61000-3-2 Limits for Harmonic Current Emissions

EN61000-3-3 Limitations of Voltage Fluctuations & Flicker in Low-Voltage Supply